

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0065:133

Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Faraday Inc, 805 South Maumee St., Tecumseh MI 49286
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Models 5233, 5234, 5235, 5243, 5244, 5245, 5253, 5254, 5255, 5263, 5264, 5265, 5373, 5374, 5375, 5383, 5384 and 5385 electronic horns; Models 5236, 5237, 5238, 5246, 5247, 5248, 5376, 5377, 5378, 5386, 5387 and 5388, may be followed by suffix -A, -B, -C, -D, -H, -N, -U, -S, -W, or -X electronic horn/strobes. *Model 5373, 5374, 5376, 5377, 5378, 5383, 5384, 5385, 5386, 5387 and 5388 are multi-tone devices. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 12 VDC, 21-32 VDC
Candela: -A, -N (15 cd), 60 flashes/min
-B, -W (15/75 cd), 60 flashes/min
-C, -D (75 cd), 60 flashes/min
-S (110 cd), 60 flashes/min

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electronic horns or horn/strobes for use with separately listed electrically compatible fire alarm control units. For indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Corrected 06-16-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 21, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager